

SINTEF Building and Infrastructure
Oslo

Forskningsveien 3b, 0373 Oslo
 P.O.Box 124 Blindern, 0314 Oslo
 Telephone: 22 96 55 55
 Telefax: 22 69 94 38

Trondheim

Høgskoleringen 7b
 7465 Trondheim
 Telephone: 73 59 33 90
 Telefax: 73 59 33 80

E-mail: byggforsk@sintef.no
 Internet: www.sintef.no/byggforsk
 Enterprise No: NO 948 007 029 MVA

Client C-Tec N.I Limited
Client's address Unit 6, Ashtree Entp. Park, Newry, Co Down, Northern Ireland BT34 1BY.
Client's contact-person Jimmy Walsh

Project/archive no. 3B0461	Date 23.03.2011	Rev. date	No. of pages 1	Appendixes	Classification Closed	Author(s) Morten Lian
Project leader Morten Lian	Sign. <i>ML</i>	Responsible manager Lars-Erik Fiskum	Sign. <i>LF</i>	Quality assurance Thale S. Plesser	Sign. <i>TS</i>	

Assignment Report

Testing of water tightness for Fibro Trespo bathroom panels using grout, type CT1 Sealant and Construction Adhesive

Summary			
Background			
SINTEF Byggforsk have on behalf of C-Tec Ltd tried water tightness of Fibro Trespo bathroom panels with use of CT1 Sealant and Construction Adhesive for sealing vertical joints, profile lists as well as in connection with pipe penetrations of bathroom panels. This is an abstract translated from the Norwegian report.			
Test Methods			
Testing was conducted in accordance to: "Guideline for European Technical Approval of watertight covering kits for wet room floors and or walls" (ETAG 022), Annex E and B. In addition, it was conducted additional tests of Annex F.			
Results			
The test is passed.			
The following components were included in the test:			
<ul style="list-style-type: none"> ▪ Fibro Trespo bathroom panels ▪ CT1 Sealant and Construction Adhesive for sealing vertical joints against profiles, around the copper pipes and bonding rubber cuffs to the wall boxes ▪ Profiles in aluminium for inside and outside corners and for lower base profile ▪ Profiles in PVC for inside and outside corners ▪ Wall boxes from Sanipex with corresponding rubberized cuffs ▪ 15 mm copper pipes ▪ Wall brackets for water basin 			
Address of the building			Built (year)
	Method Laboratory testing	Keywords Water tightness	Filename 3B0461 Fibro Trespo_ CT1, engelsk